

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220123

Product: Surge protective device (SPD) type 3

Type: DA-075-DJ25, DA-150-DJ25

Rating: DA-075-DJ25: $U_c = 75 \text{ V AC}$; $U_{oc} = 4 \text{ kV}$; $I_L = 25 \text{ A}$
DA-150-DJ25: $U_c = 150 \text{ V AC}$; $U_{oc} = 5 \text{ kV}$; $I_L = 25 \text{ A}$

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 220602-01/01 of: 18.03.2022

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:13+A11:18, (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 21.03.2025

22.03.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



220602-01