

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240044

Product: Extension cord set with multiple socket-outlet and surge protective device into 19" RACK stands

Type: RACK-PROTECTOR-X8-1U; RACK-PROTECTOR-X8-1U-5;
RACK-PROTECTOR-VX7-1U; RACK-PROTECTOR-F6-1U;
RACK-PROTECTOR-F6-1U-5; RACK-PROTECTOR-VF5-1U

Rating: 250 V/16 A/max. 3600 W, IP 40 $U_{oc} = 6 \text{ kV}$; $U_p (L-N) = 1,2 \text{ kV}$, $U_p (L/N-PE) = 1,5 \text{ kV}$

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 240096-01/01 of: 30.01.2024

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011),
ČSN IEC 60884-2-7+A1:2015 (idt IEC 60884-2-7:2011+A11:2013),
ČSN EN 35 4516:2017+Z1:2021

Other data:

The validity of the certificate is limited to: 01.02.2027

02.02.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



240096-01