

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240136

Product: Surge protective device (SPD) type 2

Type: SLP-075 V/1 (S), SLP-075 V/2 (S), SLP-150 V/1 (S), SLP-150 V/2 (S),
SLP-150 V/3 (S), SLP-150 V/4 (S), SLP-440 V/1 (S), SLP-440 V/3 (S)

Rating: $U_c = 75/150/440$ V AC,
 $I_n = 15/15/20$ kA,
 $I_{max} = 40$ kA

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 240497-01/01 of: 19.03.2024

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018
(idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 07.04.2027

08.04.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



* C E R / 1 2 4 0 1 3 6 *

240497-01