

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240332

Product: Surge protective device (SPD) Type 2+3 and Type 3 for LED lighting and similar devices

Type: DA-320-LED, SP-T2+T3-320/Y-...-LED

Rating: DA-320-LED: SPD typu 3, $U_C = 320$ V AC, $U_{oc} = 6$ kV, $I_L = 5$ A
SP-T2+T3-320/Y-...-LED: SPD typu 2+3, $U_C = 320$ V AC, $I_n = 5$ kA, $U_{oc} = 10$ kV, $I_L = 10$ A

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 241510-01/01 of: 25.06.2024

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 02.07.2027

03.07.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



* C E R / 1 2 4 0 3 3 2 *

241510-01