

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240463

Product: Surge protective device (SPD) type 2

Type: SLP-275 V/..., SLP-275 VD/..., SLP-385 V/..., SLP-385 VD/...,
SLP-NPE V/..., SLP-NPE VD/... (see Annex)

Rating: L-N (L-PEN): $U_C = 275 / 385$ V AC, $I_n = 20$ kA, $I_{max} = 40$ kA
N-PE: $U_C = 255$ V AC, $I_n = 20$ kA, $I_{max} = 40$ kA

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 242065-01/01 of: 27.09.2024

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 30.09.2027

01.10.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



242065-01

Type series:

SLP-275 V/1	SLP-385 V/1	SLP-NPE V/1
SLP-275 V/1 S	SLP-385 V/1 S	SLP-NPE VD/1
SLP-275 V/1+1	SLP-385 V/1+1	SLP-NPE VDS/1
SLP-275 V/1S+1	SLP-385 V/1S+1	
SLP-275 V/2	SLP-385 V/2	
SLP-275 V/2 S	SLP-385 V/2 S	
SLP-275 V/2+1	SLP-385 V/2+1	
SLP-275 V/2S+1	SLP-385 V/2S+1	
SLP-275 V/3	SLP-385 V/3	
SLP-275 V/3 S	SLP-385 V/3 S	
SLP-275 V/3+1	SLP-385 V/3+1	
SLP-275 V/3S+1	SLP-385 V/3S+1	
SLP-275 V/4	SLP-385 V/4	
SLP-275 V/4 S	SLP-385 V/4 S	
SLP-275 VD/1+1	SLP-385 VD/1+1	
SLP-275 VD/2+1	SLP-385 VD/2+1	
SLP-275 VD/3+1	SLP-385 VD/3+1	
SLP-275 VDS/1+1	SLP-385 VDS/1+1	
SLP-275 VDS/2+1	SLP-385 VDS/2+1	
SLP-275 VDS/3+1	SLP-385 VDS/3+1	

