

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1250311

**Product:** Surge protective device (SPD) for data, signalling and telecommunications networks

**Type:** DL-10G-PoE-IP66

**Rating:**  $U_c = 8,5/58$  V DC,  $I_L = 500$  mA, IP66, category C2, C3, D1

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 251786-01/01 of: 21.07.2025

A sample of the product was found to be in conformity with:  
ČSN EN 61643-21:2002+A1:2010+A2:2013 (idt EN 61643-21:2001+A1:2009+A2:2013)

**Other data:**

The validity of the certificate is limited to: 24.07.2028

25.07.2025

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



251786-01