

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1250312

Product: Surge protective device (SPD) type 1 and type 2

Type: FLP-12,5-075-VH/1(S), FLP-12,5-075-VH/2(S)

Rating: $U_C = 75 \text{ V AC/DC}$, $I_n = 20 \text{ kA}$, $I_{imp} = 12,5 \text{ kA}$, $I_{max} = 40 \text{ kA}$

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 251787-01/01 of: 21.07.2025

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 24.07.2028

25.07.2025

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



251787-01