

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1250492

Product: Surge protective device (SPD) type 3

Type: DA-275 V/1+1, DA-275 V/1S+1, DA-275 V/3+1, DA-275 V/3S+1

Rating: L-N: $U_c = 275 \text{ V AC}$, $U_{oc} = 10 \text{ kV}$, $U_p = 1,0 \text{ kV}$,
N-PE: $U_c = 255 \text{ V AC}$, $U_{oc} = 20 \text{ kV}$, $U_p = 1,5 \text{ kV}$

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Factories: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 252729-01/01 of: 11.12.2025

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 15.12.2028

16.12.2025

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



252729-01