ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV

ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЗЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1260359

Product: Surge protective device (SPD) type 1 and type 2

Type: FLP-12,5 V/1 (S), FLP-12,5 V/1(S)+1, FLP-12,5 V/2 (S), FLP-12,5 V/3 (S), FLP-12,5 V/3(S)+1, FLP-12,5 V/4 (S)

Rating: L-N: U_C = 275 V AC, I_n = 30 kA, I_{imp} = 12,5 kA, I_{max} = 60 kA,
N-PE 25: U_C = 255 V AC, I_n = 30 kA, I_{imp} = 25 kA, I_{max} = 60 kA,
N-PE 50: U_C = 255 V AC, I_n = 50 kA, I_{imp} = 50 kA, I_{max} = 100 kA

Ordering firm: SALTEK a.s.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK a.s.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 262108-01/01 of: 16.09.2026

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 28.09.2029

29.09.2026

Prague

Mgr. Miroslav Sedláček
Head of Certification Body

elektrotechnický zkušební ústav ezú Pod lisem 129/2, Troja, 182 00 Praha 8

Stamp

CER/1260359

262108-01